

在編程 ENA 系列網路分析儀
時，出現錯誤訊息 "-128,
Numeric data not
allowed" (-128, 不允許的數字
資料)。為什麼？

Notices

© Keysight Technologies Incorporated, 2002-2020

1400 Fountaingrove Pkwy., Santa Rosa, CA 95403-1738, United States All rights reserved.

No part of this documentation may be reproduced in any form or by any means (including electronic storage and retrieval or translation into a foreign language) without prior agreement and written consent from Keysight Technologies, Inc. as governed by United States and international copyright laws.

Restricted Rights Legend

If software is for use in the performance of a U.S. Government prime contract or subcontract, Software is delivered and licensed as "Commercial computer software" as defined in DFAR 252.227-7014 (June 1995), or as a "commercial item" as defined in FAR 2.101(a) or as "Restricted computer software" as defined in FAR 52.227-19 (June 1987) or any equivalent agency regulation or contract clause.

Use, duplication or disclosure of Software is subject to Keysight Technologies' standard commercial license terms, and non-DOD Departments and Agencies of the U.S. Government will receive no greater than Restricted Rights as defined in FAR 52.227-19(c)(1-2) (June 1987). U.S. Government users will receive no greater than Limited Rights as defined in FAR 52.227-14 (June 1987) or DFAR 252.227-7015 (b)(2) (November 1995), as applicable in any technical data.

Portions of this software are licensed by third parties including open source terms and conditions.

For detail information on third party licenses, see [Notice](#).

在編程 ENA 系列網路分析儀時，出現錯誤訊息 "-128, Numeric data not allowed" (-128, 不允許的數字資料)。為什麼？


Contents

在編程 ENA 系列網路分析儀時，出現錯誤訊息 "-128, Numeric data not allowed" (-128, 不允許的數字資料)。為什麼？

(支援的型號以**粗體字**標示：**E5071C E5072A E5070B/71B E5070A/71A E5061A/62A E5061B E5063A E5091A E5092A**)

對許多分析儀來說，可自分析儀輸出資料時調整資料傳送的格式，亦即可針對從分析儀至控制電腦的輸入。針對 ENA 系列分析儀，可以選取資料輸出 (從 ENA 到控制器) 與資料輸入模式 (從控制器到 ENA)。若出現 "-128, Numeric data not allowed" 錯誤訊息，透過命令 "FORMat:DATA {ASCIi|REAL|REAL32}" 調整傳送格式。命令同時影響輸入及輸出資料的傳送。

下圖為 Keysight VEE 7.x 版程式的影像，概略說明錯誤的發生以，及如何利用 FORM 命令修正錯誤。



放大圖

